

SmartStack™

Using Active Sensing to Safely
Improve Lab Exhaust Efficiency

Rev 1.03

About This Document

This document describes many aspects of exhaust fan performance, especially as it relates to an exhaust system's ability to perform safely when handling a wide range of chemical compounds that may and sometimes will be released in lab spaces. Measured Air Performance (MAP) makes no representations or warranties of any kind with respect to the information in this publication. The information in the publication is provided "as is" and we do not guarantee the accuracy of this content. Although MAP believes the information in this publication is accurate as of its publishing date, the information is subject to change without notice. As applications of use will vary, the information provided is given without legal responsibility.

Copyright 2018 Measured Air Performance, LLC. All rights reserved.

SmartStack is a trademark of Measured Air Performance, LLC.

Introduction:

In most labs, there are typically only a few active fume hoods in the system emitting limited levels of contaminants. These contaminants are significantly diluted by the relatively clean air that is manifolded from other locations. Although, the laboratories operate in these relatively clean states for extended periods of time, the exhaust fan systems run at high exit velocities (e.g., 3,000 ft/min or higher). As a result, these systems frequently operate at much higher total flow rates than required using significantly more energy than necessary. Many assume that exhaust fans are required to operate at 3,000 ft/min (minimum). However, this setting is only a recommendation from ANSI Z9.5. The standard also states lower velocities can be used, provided there is sufficient dilution, as indicated below.

"The exhaust stack velocity shall be at least 3,000 ft/min (15.2 m/s) is required unless it can be demonstrated that a specific design meets the dilution criteria necessary to reduce the concentration of hazardous materials in the exhaust to safe levels at all potential receptors."

SmartStack™ ensures dilution criteria are met and concentrations of hazardous materials are at safe levels, while maximizing energy savings. SmartStack™ is an active sensing system that monitors the cleanliness of lab exhaust air and provides a signal to the fan controls or building automation system to index the exit velocity of the fans accordingly. The purpose of this system is to reduce excess exhaust fan energy use when it is safe to do so, either by way of bypass air reductions or, in some applications, by enabling lab air change rate reductions. This results in fan exit velocities that are less than 3,000 ft/min, when it's safe to operate in this mode. Such lower exit velocities are enabled when SmartStack™ determines that the exhaust air is clean. Also, in many applications fan exit velocities may have initially been set to values much higher than 3000 ft/min. Sometimes this is the result of an undersized fan nozzle; in which case it may not be possible to reduce much below 3000 ft/min as bypass air is reduced. However, that's not viewed as a constraint to energy savings. The important thing is, by applying fan setback when the exhaust is clean, it provides a way to reduce excess bypass air.

The Inefficiency of Excess Fan Dilution:

Figure 1 helps to illustrate the common characteristics of high plume fan systems in terms of their tendency to provide dispersive dilution of contaminants with exit velocity. The actual dilution performance will vary considerably based on the vertical height of the fan and its surroundings. However, notice that the curve relating dilution levels to exit velocity is concave down. This means that, with an increase in CFM and exit velocity through the fan, you do not get a proportionally similar increase in dilution from the fan's exit plume. What this also means is that small reductions in fan exit velocity (when the exhaust is clean) will result in even smaller reductions in the overall dilution provided by the system. Further, fan affinity laws suggest a cubic relationship between flow and power. In most cases, because of system efficiency issues the power relationship is not quite cubic but is often still exponential nonetheless. Table 1 illustrates this further. In this example, a reduction in fan exit velocity by 31% (from 4400 fpm to 3000 fpm) results in an 8.4% reduction in dispersive dilution (from 483 to 442). However, the power savings in this example (assuming slightly less than cubic law performance) is approximately 62% (from 88 kW to 32.7kW).




Figure 1: Example Relationship of Dilution with Exit Velocity

Fan Power (KW)	Fan (CFM)	Exit Velocity (Ft/min)	Dispersive Dilution
88	55,000	4400	483
32.7	37,000	3000	442
19.4	30,000	2400	421

Table 1: Illustration of power savings with exit velocity

How it Works – SmartStack™ Applied to an Exhaust Fan System

The SmartStack™ system incorporates a multi-point air sampling approach that monitors a location on each riser that is manifolded to the fan set. One SmartStack™ system is applied to each fan set and air samples are continuously drawn from each riser in a sequential fashion and analyzed by the system using a photoionization detector (PID) sensor technology that is integrated within the system. The PID is capable of detecting hundreds of compounds commonly found in laboratory facilities and is a technology that is recognized by health and safety professionals worldwide. Once all of the monitoring points have been verified to be free of contaminants, SmartStack™ then issues a “setback” command to the specific exhaust fan controls. In doing so, the fan system will reduce its exit velocity by way of a reduction in bypass air. Only the amount of bypass air is affected during this setback condition. As soon as contaminants are detected at any of the risers, the system will switch out of setback and into a mode that protects the PID (“sensor protective mode”) that is intrinsic to the system. Approximately 20




Figure 2: Multi-Riser Exhaust System

minutes after the detection of contaminants, the system will resume taking air samples to see if the sampled locations still have high contaminant levels. If so, the system will go back into sensor protective mode with setback disabled. The process continues until the system is able to verify that all monitored locations are free of contaminants, before once again issuing a setback command.

In other applications where bypass air is not present, SmartStack™ can be used to not only save on exhaust fan energy but supply fan energy and heating and cooling energy. This is accomplished by lowering lab minimum air change rates when the fan exhaust is free of contaminants. This method provides a way to reduce lab air changes in scenarios where lower air changes result in fan exit velocities of less than 3000 feet per minute. With this approach, reduced air change rates are implemented via the lab controls based on the SmartStack™ setback signal.

SmartStack™ Photoionization Detector:

At the heart of SmartStack™ is our photoionization detector technology. A photoionization detector (PID) is a gas sensing technology capable of sensing hundreds of different compounds commonly found in lab environments. PID's have been in use (particularly as handheld instruments) for many decades and are especially recognized by Environmental Health and Safety (EH&S) professionals, due to their sensitivity. Such technology is also used in trace level sensing equipment, including gas chromatography-mass spectrometry due to their excellent sensing resolution. SmartStack™ incorporates a specialized PID design that provides low power performance, excellent stability, and the best sensitivity found in industry. This instrument provides detection capabilities of concentrations down to a few parts per billion (ppb). This is incorporated along with a patent pending mechanism that is used to protect the sensor from prolonged over-exposure, when high contaminant concentrations are detected and is an important enabling capability to this application. Without this capability, a PID would tend to foul and drift with prolonged exposure, thus affecting the detection reliability important to properly controlling the fan.

Figure 3 is a simplified illustration of the PID design. It incorporates an ultraviolet (UV) lamp as an ionization source and a collector electrode which serves as the detector. The air being analyzed flows through the sensor chamber and is exposed to the lamp. The sensor detects compounds based on the affinity for the gas to be ionized by the UV source. Ionization takes place when the compound's ionization potential is less than the energy level of the photons emitted from the lamp. Currently, our PID incorporates a lamp design which outputs an energy level of 10.7 electron volts (eV). This tends to be the most popular eV level used in industry because lamps at this energy level (made from a krypton filament) tend to be highly reliable and a vast number of compounds will ionize at this level. The way that this works is that if the compound's ionization potential is lower than 10.7 eV, then it can be ionized and thus detected. For example, from the appendix below benzene has an ionization potential of 9.25 eV; therefore, it can be detected. Further, Chloroform has an ionization potential of 11.37 eV and therefore will not be detected. (See the section below explaining why some compounds such as Chloroform may not need to be detected in this application.) When a gas molecule becomes ionized, it becomes positively charged. This causes its charge to be drawn to the negative electrode causing an electrical current to flow. The level of molecular ionization and the current that is produced is proportional to the gas concentration that is present.

Another aspect of the PID's operation to be aware of is that different gases will generate different responses, even though their ionization potential may be less than 10.7 eV. This characteristic is known as a response factor or "RF". With the tables in the Appendix, a column is provided which lists the RF values for each compound. The RF value is an indication of the ratio of the sensor's sensitivity to a specific gas (isobutylene) to that of the given compound. For example, ammonia has a response factor of 9.4, which means that the sensor's response to ammonia is




Figure 3: Simplified PID Schematic

9.4 times lower than its response to isobutylene. On the other hand, the sensor's RF for benzene is .5, which means that the PID is twice as sensitive to benzene as it is to isobutylene.

Exhaust System Dilution with Chemical Inventory:

Usually, when a lab exhaust system is designed, much attention is given to the types of compounds that may be used in the lab spaces. Properties of the chemical inventory including not only exposure limits and odor thresholds but also the ease with which a compound may become airborne is factored into this analysis. The performance that's needed from the system is then assessed by considering a spill condition (usually at a fume hood) for each compound in question. When evaluating exposure potentials from compounds that are liquids or solids, a fixed spill area is often applied. This usually will correlate to the area of a popular fume hood size (such as a 5-foot hood for example). Because of the fixed spill area, quantities of 1 liter are often assumed. Some compounds are too potent to be used in 1-liter quantities and will usually require a quantity limitation protocol that is independent of whether or not SmartStack™ is applied. For gas phase compounds, the analysis will usually assume a certain leakage or fugitive emissions rate from a canister.

Especially for liquids and certain solids, the vapor pressure of the compound will significantly influence the dispersion characteristics of the material in question, as well as the concentration of that material that might be seen at the exhaust fan inlet in the event of a spill. Even though SmartStack™ is capable of sensing hundreds of different compounds that may be found in a lab, it's important to realize that the dilution requirements of the exhaust fan system vary greatly due to the vapor pressure variations of the compounds. In the event of a spill, many compounds may not appear in high concentrations at the fan inlet. For example, sulfuric acid, a compound which is quite toxic to the touch, has a very low vapor pressure; so low that even a large spill in a fume hood would hardly influence airborne concentrations seen at the fan inlet.

Another factor which can significantly influence fan dilution requirements is the "internal dilution" provided by the manifolded exhaust from each lab space. The

airflow from a single fume hood where a spill takes place will often be diluted by a factor of 40 or more by the clean air from other spaces.

The appendix includes a detailed list of over 350 compounds which are found in chemical inventories. This includes many compounds which are often used in labs along with a number of materials which have more specialized use, including some potent compounds which often require quantity limitation protocols. The list in the appendix not only demonstrates which compounds are detected by SmartStack™ but also models the result of a spill by each compound. For liquids and solids, the spill condition assumes a fume hood spill area of about 9ft² and an air flow rate of 900 CFM. It also assumes a very conservative figure for the internal dilution rate of the exhaust system by a factor of 15. For gas phase compounds, the spill condition assumes a fugitive emission at a rate of 4 liters per minute.

Although the majority of the compounds in this list are detected by the SmartStack™ system, some of these compounds need not be detected because of their relatively low impact on the dilution requirements to be provided by the fan system. This is measured in the “Fan Inlet Spill Concentration” column, which provides a measure of the dilution required of the fan. For example, a spill of Acetic Acid would result in concentrations that are only a factor of .3 of that compound’s health limit and only a factor of 23.7 of that compound’s odor threshold. So, in this case although the odor threshold at the fan’s inlet will be exceeded by a factor of 23, the fan itself should be able to provide more than enough dilution to address those levels. It should be clear however that, in the application of SmartStack™ the fan would not be held in a setback condition as concentrations of this compound are detected.

There are also a few compounds in this list which are not detected by SmartStack™, most of which are compounds which would normally not need to be detected because of their low vapor pressures (sulfuric acid for example). However, there are also a smaller number of compounds which are not detected that would normally require a quantity limitation protocol (Boron Trifluoride, for example), due to their abnormally high toxicity, low odor threshold, and high vapor pressure.

Lastly, many EH&S personnel require that extremely toxic compounds be used only in designated fume hoods, with strict protocols. Irrespective of SmartStack™'s ability to detect these compounds, the system is able to interface with an occupancy sensor signal from these fume hoods and disable the fan setback when anyone is working at or near these fume hoods. This feature can also apply to an occupancy signal detecting presence of anyone in the entire lab.

Noise Reduction

Fan noise can be an issue that requires mitigation, particularly when the fans are located near non-industrial locations such as neighborhoods, schools, or other locations where occupants may be less tolerant to noisy conditions. Noise levels are also of concern in many vivariums or animal holding facilities, for example. Mitigation may also be necessary to meet local code requirements.

Reducing fan exit velocity can drive not only dramatic energy savings, but can also result in reductions in noise levels that can often be significant. Figure 4 shows a typical scenario where there is approximately a 3:1 ratio of fan operating speed reduction to net sound pressure level reduction. Actual results will vary based on the fan geometry, its surroundings, and fan operating conditions, such as fan total static pressure.




Figure 4: Net Sound Level vs. Fan Operating Speed. Chart Courtesy of Strobic Air Corporation

In certain cases, SmartStack™ may be the most effective noise abatement solution as compared to mechanical isolation, silencers, blade rebalancing, or the addition of expensive barriers or sound absorbing materials.

APPENDIX: Exhaust System Performance and Spill Detection:

This appendix tabulates the performance of an exhaust fan system equipped with SmartStack™ and subjected to spill conditions for over 350 of the most frequently used liquid or gas phase compounds in labs. The spill condition assumptions and operational characteristics of the exhaust system are stated below. Generally, the compounds which have higher vapor pressures and lower toxic limit values or odor threshold values will require more dilution from the exhaust fan system. Along with tabulating whether a compound is detected by SmartStack™'s PID sensor, concentrations at the fan inlet are estimated for each compound based both on health limits and odor thresholds. Note that in many cases, concentrations may be well above exposure limits at the fan, it is then the dispersive dilution provided by the fan system which prevents over exposure at receptor points around the lab facility. For this analysis, we assume the plume will provide at least 400:1 dilution to any contaminants at the fan inlet. In practice, dilution levels will usually be higher than this, when on accounts for the dilution provided at the fan's windband and, when present, the dilution provided by bypass air.

Assumptions:

Hood Flow at Spill:	900 CFM
Hood Surface Area:	9 ft ²
Fugitive Emission Rate when gas:	4 Liters per minute
Liquid Spill Quantity:	1 Liter
Building Internal Dilution:	15:1
Fan Dilution:	400:1

APPENDIX: Exhaust System Performance and Spill Detection

#	Compound	CAS Number	Liquid or Gas	RF	IP(eV)	Health Limits (PPM)	Odor Threshold (PPM)	OEL Type	OEL Agency	Detect?	Fan Inlet Spill Concentrations		Adequate Detection?
											Factor Above Health Limit	Factor Above Odor Threshold	
1	Acetaldehyde	75-07-0	Liquid	10.80	10.21	25.01	0.050	Ceil	ACGIH	YES	8.8	4419.5	QLP*
2	Acetic Acid	64-19-7	Liquid	11.00	10.69	15.05	0.160	STEL	ACGIH	YES	0.3	23.7	YES
3	Acetic Anhydride	108-24-7	Liquid	4.00	10	4.79		Ceil	NIOSH	YES	0.2	0.0	YES
4	Acetone	67-64-1	Liquid	1.20	9.69	749.91		STEL	ACGIH	YES	0.1	0.0	YES
5	Acetonitrile	75-05-8	Liquid	-	NA	60.68		TWA	ACGIH	NO	0.4	0.0	YES
6	Acetophenone	98-86-2	Liquid	0.59	9.27	29.95		TWA	ACGIH	YES	0.0	0.0	YES
7	Acetylene	74-86-2	Gas	-	-	None				NO	0.0	0.0	YES
8	Acrolein	107-02-8	Liquid	3.90	10.1	0.10	0.174	Ceil	ACGIH	YES	679.0	391.2	QLP*
9	Acrylic Acid	79-10-7	Liquid	2.70	10.6	6.01		TWA	ACGIH	YES	0.1	0.0	YES
10	Acrylonitrile	107-13-1	Liquid	-	-	2.00		TWA	ACGIH	NO	12.4	0.0	YES
11	Allyl Alcohol	107-18-6	Liquid	2.50	9.67	4.21		STEL	ACGIH	YES	1.2	0.0	YES
12	Allyl Chloride	107-05-1	Liquid	4.50	9.9	1.92	0.489	STEL	ACGIH	YES	0.1	0.4	YES
13	Ammonia	7664-41-7	Gas	9.40	10.2	35.00	5.000	STEL	ACGIH	YES	0.3	1.9	YES
14	Amyl Acetate (n-)	628-63-7	Liquid	3.50		99.90	0.100	STEL	ACGIH	YES	0.1	89.6	YES
15	Amyl Acetate (sec-)	626-38-0	Liquid	3.50		125.00	0.100	STEL	ACGIH	YES	0.0	20.9	YES
16	Amyl Alcohol	71-41-0	Liquid	3.20	10	1000.00				YES	0.0	0.0	YES
17	Aniline	62-53-3	Liquid	0.50	7.7	5.99		TWA	ACGIH	YES	0.0	0.0	YES
18	Anisole	100-66-3	Liquid	0.50	8.2	1000.000				YES	0.0	0.0	YES
19	Arsine	7784-42-1	Gas	2.60	9.89	0.01	0.500	Ceil	NIOSH	YES	1927.0	19.3	QLP*
20	Benzaldehyde	100-52-7	Liquid	0.90	9.5	1000.00				YES	0.0	0.0	YES
21	Benzene	71-43-2	Liquid	0.53	9.25	1.00	1.250	STEL	NIOSH	YES	28.4	22.8	YES
22	Benzenethiol	108-98-5	Liquid	0.70		1000.00				YES	0.0	0.0	YES
23	Benzonitrile	100-47-0	Liquid	0.70	9.6	1000.00				YES	0.0	0.0	YES
24	Benzyl Alcohol	100-51-6	Liquid	1.30		1000.00				YES	0.0	0.0	YES
25	Benzyl Chloride	100-44-7	Liquid	0.60	10.2	0.97		Ceil	NIOSH	YES	0.3	0.0	YES
26	Benzyl Formate	104-57-4	Liquid	0.80		1000.00				YES	0.0	0.0	YES
27	Biphenyl	92-52-4	Solid	0.40		0.60		TWA	NIOSH	YES	0.0	0.0	YES
28	Bis(2,3-epoxypropyl) ether	2238-07-5	Liquid	3.00		0.53		Ceil	OSHA	YES	0.1	0.0	YES
29	Boron Tribromide	10294-33-4	Liquid	1.30	9.7	1.00		REL	NIOSH	YES	12.0	0.0	YES
30	Boron Trifluoride	7637-07-2	Gas	-	15.56	0.10		TWA	ACGIH	NO	96.3	0.0	YES
31	Bromine	7726-95-6	Liquid	10.54	10.51	0.20	0.066	STEL	ACGIH	YES	265.9	801.4	QLP*
32	Bromine Pentafluoride	7789-30-2	Liquid	-		0.10		TWA	ACGIH	NO	979.4	0.0	QLP*
33	Bromobenzene	108-86-1	Liquid	0.70	9	1000.00		STEL	ACGIH	YES	0.0	0.0	YES
34	Bromoethane	74-96-4	Liquid	5.00		14.80		TWA	ACGIH	YES	7.6	0.0	YES
35	Bromoethyl methyl ether, 2-	6482-24-2	Liquid	2.50		1000.00		STEL	ACGIH	YES	0.0	0.0	YES
36	Bromoform	75-25-2	Liquid	2.30	10.48	1.45		TWA	ACGIH	YES	1.0	0.0	YES
37	Bromomethane	74-83-9	Gas	1.80	10.54	20.59		Ceil	ACGIH	YES	0.5	0.0	YES
38	Bromopropane, 1-	106-94-5	Liquid	1.30		29.82		TWA	ACGIH	YES	1.1	0.0	YES
39	Butadiene diepoxide, 1,3-	1464-53-5	Liquid	4.00		1000.00				YES	0.0	0.0	YES
40	Butadiene, 1,3-	106-99-0	Gas	0.69	9.07	4.97	0.455	STEL	OSHA	YES	1.9	21.2	YES
41	Butane, n-	106-97-8	Gas	46.30	10.5	2402.02		TWA	ACGIH	YES	0.0	0.0	YES
42	Butanol, 1-	71-36-3	Liquid	3.40	10.04	49.49		Ceil	NIOSH	YES	0.0	0.0	YES
43	Buten-3-ol, 1-	598-32-3	Liquid	1.20		1000.00				YES	0.0	0.0	YES
44	Butene, 1-	106-98-9	Gas	1.30	9.5	750.50		TWA	ACGIH	YES	0.0	0.0	YES
45	Butoxyethanol, 2-	111-76-2	Liquid	1.30	10	14.90		TWA	NIOSH	YES	0.0	0.0	YES
46	Butyl Acetate	123-86-4	Liquid	2.40	10	199.89		STEL	ACGIH	YES	0.0	0.0	YES
47	Butyl Acrylate, n-	141-32-2	Liquid	1.50		6.94		TWA	ACGIH	YES	0.2	0.0	YES
48	Butyl Alcohol (n-)	71-36-3	Liquid	4.70	10.04	100.00		TWA	NIOSH	YES	0.0	0.0	YES
49	Butyl Alcohol (sec-)	78-92-2	Liquid	3.00	10.04	100.00		TWA	NIOSH	YES	0.0	0.0	YES
50	Butyl alcohol, tert-	75-65-0	Liquid	3.44	10.04	148.48		STEL	NIOSH	YES	0.1	0.0	YES
51	Butyl Lactate	138-22-7	Liquid	2.50		12.54		TWA	NIOSH	YES	0.0	0.0	YES
52	Butyl mercaptan, tert-	109-79-5	Liquid	0.55	9.15	0.49	0.010	Ceil	NIOSH	YES	189.7	9255.9	QLP*

* "QLP" means Quantity Limitation Protocol Recommended

Compound	CAS Number	Liquid or Gas	RF	IP(eV)	Health Limits (PPM)	Odor Threshold (PPM)	OEL Type	OEL Agency	Detect?	Fan Inlet Spill Concentrations		Adequate Detection?
										Factor Above Health Limit	Factor Above Odor Threshold	
53 Butylamine, n-	109-73-9	Liquid	1.00	8.71	5.01	0.053	Ceiling	OSHA	YES	4.9	462.3	QLP*
54 Butylamine, tert-	75-64-9	Liquid	0.71	8.7	1000.00				YES	0.1	0.0	YES
55 Carbon Disulfide	75-15-0	Liquid	1.20	10.07	9.64	0.096	STEL	NIOSH	YES	9.5	952.5	QLP*
56 Carbon tetrabromide	558-13-4	Solid	3.00		0.30		STEL	NIOSH	YES	39.8	0.0	YES
57 Carbon Tetrachloride	56-23-5	Liquid	-		10.00		STEL	ACGIH	NO	2.7	0.0	YES
58 Carvone, R-	6485-40-1	Liquid	1.00		1000.00				YES	0.0	0.0	YES
59 Chlorine	7782-50-5	Gas	-	11.48	0.50		Ceiling	ACGIH	NO	19.3	0.0	YES
60 Chlorine Dioxide	10049-04-4	Gas	1.00	10.36	0.30		STEL	ACGIH	YES	32.0	0.0	YES
61 Chloro-1,3-butadiene, 2-	126-99-8	Liquid	3.20	8.8	0.99		Ceiling	NIOSH	YES	52.3	0.0	YES
62 Chlorobenzene	108-90-7	Liquid	0.40	9.07	29.97		TWA	ACGIH	YES	0.1	0.0	YES
63 Chloroethanol, 2-	107-07-3	Liquid	10.00	10.5	0.91		Ceiling	NIOSH	YES	1.6	0.0	YES
64 Chloroform	67-66-3	Liquid	-	11.37	10.00		TWA	ACGIH	NO	5.8	0.0	YES
65 Chloromethyl Ether (bis-)	542-88-1	Liquid	-		0.001		TWA	ACGIH	NO	8964.6	0.0	QLP*
66 Chloropicrin	76-06-2	Liquid	400.00		0.10		TWA	ACGIH	YES	53.8	0.0	YES
67 Chloroprene (Beta-)	126-99-8	Liquid	1.30	8.79	10.00		TWA	ACGIH	YES	5.6	0.0	YES
68 Chlorotoluene, o-	95-49-8	Liquid	0.50	8.8	72.19		STEL	OSHA	YES	0.0	0.0	YES
69 Chlorotoluene, p-	108-41-8	Liquid	0.50	8.7	1000.00		STEL	OSHA	YES	0.0	0.0	YES
70 Chlorotrifluoroethylene	79-38-9	Gas	1.00	9.81	29.00		AEG	EPA	YES	0.3	0.0	YES
71 Citral	5392-40-5	Liquid	1.70		1000.00				YES	0.0	0.0	YES
72 Citronellol	26489-01-0	Liquid	1.00	8.5	1000.00				YES	0.0	0.0	YES
73 Cresol, m-	108-39-4	Solid	1.10	8.14	2.30		TWA	NIOSH	YES	0.0	0.0	YES
74 Cresol, o-	95-48-7	Solid	1.10	8.14	2.30		TWA	NIOSH	YES	0.0	0.0	YES
75 Cresol, p-	106-44-5	Solid	1.10	8.14	2.30		TWA	NIOSH	YES	0.0	0.0	YES
76 Crotonaldehyde	4170-30-3	Liquid	1.00	9.7	2.00		Ceiling	ACGIH	YES	2.8	0.0	YES
77 Cumene (Isopropyl Benzene)	98-82-8	Liquid	0.54	8.75	149.51	0.100	TWA	OSHA	YES	0.0	23.9	YES
78 Cyanogen	460-19-5	Gas	-		10.00				NO	1.0	0.0	YES
79 Cyclohexane	110-82-7	Liquid	1.50	9.8	300.00		TWA	ACGIH	YES	0.1	0.0	YES
80 Cyclohexanol	108-93-0	Liquid	1.60	10	50.00		TWA	ACGIH	YES	0.0	0.0	YES
81 Cyclohexanone	108-94-1	Liquid	0.82	9.14	25.00		TWA	ACGIH	YES	0.1	0.0	YES
82 Cyclohexene	110-83-8	Liquid	0.80	8.9	300.00		TWA	ACGIH	YES	0.1	0.0	YES
83 Cyclohexylamine	108-91-8	Liquid	1.00	8.6	10.00		TWA	NIOSH	YES	0.3	0.0	YES
84 Cyclopentane	287-92-3	Liquid	4.00	10.5	600.00		TWA	ACGIH	YES	0.2	0.0	YES
85 Decane	124-18-5	Liquid	1.60	9.6	500.00		TWA	NIOSH	YES	0.0	0.0	YES
86 Dibenzoyl peroxide	94-36-0	Solid	0.80		1.50		TWA	NIOSH	YES	0.1	0.0	YES
87 Dibromochloromethane	124-48-1	Liquid	10.00		1000.00				YES	0.0	0.0	YES
88 Dibromoethane, 1,2-	106-93-4	Liquid	2.00	9.45	0.13		Ceiling	NIOSH	YES	27.5	0.0	YES
89 Dibutyl hydrogen phosphate	107-66-4	Liquid	4.00		1.16		STEL	ACGIH	YES	0.3	0.0	YES
90 Dichloro-1-propene, 2,3-	78-88-6	Liquid	1.40		1000.00				YES	0.0	0.0	YES
91 Dichloroacetylene	7572-29-4	Liquid	5.00		0.10		Ceiling	ACGIH	YES	362.8	0.0	YES
92 Dichlorobenzene, 1,2-	95-50-1	Liquid	0.50	9.06	49.90		Ceiling	OSHA	YES	0.0	0.0	YES
93 Dichloroethene, cis-1,2-	156-59-2	Liquid	0.80	9.7	597.39		TWA	OSHA	YES	0.0	0.0	YES
94 Dichloroethylene, trans-1,2-	156-60-5	Liquid	0.45	9.7	597.39		TWA	OSHA	YES	0.0	0.0	YES
95 Dichloroethylene, 1,2-	540-59-0	Liquid	0.70	9.7	597.39		TWA	OSHA	YES	0.1	0.0	YES
96 Dicyclopentadiene	77-73-6	Solid	0.90		5.00		TWA	NIOSH	YES	0.1	0.0	YES
97 Diesel fuel #1	68334-30-5	Liquid	0.90	<10.6	45.00		TWA	ACGIH	YES	0.0	0.0	YES
98 Diesel fuel #2	68334-30-5	Liquid	0.75	<10.6	45.00		TWA	ACGIH	YES	0.0	0.0	YES
99 Diethyl maleate	141-05-9	Liquid	2.00		1000.00				YES	0.0	0.0	YES
100 Diethyl phthalate	84-66-2	Liquid	1.00		1.65		TWA	ACGIH	YES	0.0	0.0	YES
101 Diethyl sulphate	64-67-5	Liquid	3.00		1000.00				YES	0.0	0.0	YES

* "QLP" means Quantity Limitation Protocol Recommended

Compound	CAS Number	Liquid or Gas	RF	IP(eV)	Health Limits (PPM)	Odor Threshold (PPM)	OEL Type	OEL Agency	Detect?	Fan Inlet Spill Concentrations		Adequate Detection?
										Factor Above Health Limit	Factor Above Odor Threshold	
102 Diethyl sulphide	352-93-2	Liquid	0.60		1000.00				YES	0.0	0.0	YES
103 Diethylamine	109-89-7	Liquid	1.00	8.01	10.00	0.140	STEL	ACGIH	YES	5.7	409.8	YES
104 Diethylaminoethanol, 2-	100-37-8	Liquid	2.70		10.00		TWA	NIOSH	YES	0.0	0.0	YES
105 Diethylaminopropylamine, 3-	104-78-9	Liquid	1.00		1000.00				YES	0.0	0.0	YES
106 Dihydrogen Selenide	7783-07-5	Gas	1.00		0.14	0.300	TWA	ACGIH	YES	66.5	32.1	YES
107 Dihydroxybenzene, 1,2-	120-80-9	Solid	1.00		5.00		TWA	NIOSH	YES	0.6	0.0	YES
108 Dihydroxybenzene, 1,3-	108-46-3	Solid	1.00		10.00		STEL	NIOSH	YES	0.0	0.0	YES
109 Diisobutylene	107-39-1	Liquid	0.60		1000.00				YES	0.0	0.0	YES
110 Diisopropylamine	108-18-9	Liquid	0.70		5.00	0.398	TWA	OSHA	YES	4.2	52.5	YES
111 Diketene	674-82-8	Liquid	2.20		1000.00				YES	0.0	0.0	YES
112 Dimethoxymethane	109-87-5	Liquid	11.30	10	1000.00		TWA	OSHA	YES	0.1	0.0	YES
113 Dimethyl cyclohexane, 1,2-	583-57-3	Liquid	1.10		1000.00				YES	0.0	0.0	YES
114 Dimethyl ether	115-10-6	Gas	1.30		1000.00				YES	0.0	0.0	YES
115 Dimethyl phthalate	131-11-3	Liquid	1.00	9.64	1.89		TWA	OSHA	YES	0.0	0.0	YES
116 Dimethylacetamide, N,N-	127-19-5	Liquid	0.73	8.81	10.00		TWA	OSHA	YES	0.1	0.0	YES
117 Dimethylamine	124-40-3	Gas	1.40	8.23	10.00	0.081	STEL	ACGIH	YES	1.0	118.9	YES
118 Dimethylaminoethanol	108-01-0	Liquid	1.50		1000.00				YES	0.0	0.0	YES
119 Dimethylaniline, N,N-	121-69-7	Liquid	0.60	7.13	10.09		STEL	ACGIH	YES	0.0	0.0	YES
120 Dimethylbutyl acetate	108-84-9	Liquid	1.60		50.00		TWA	ACGIH	YES	0.0	0.0	YES
121 Dimethyldisulfide	624-92-0	Liquid	0.30	8.69	1.56		TWA	ACGIH	YES	5.5	0.0	YES
122 Dimethylethylamine, N,N-	598-56-1	Liquid	0.80		1000.00				YES	0.1	0.0	YES
123 Dimethylformamide, N,N-	68-12-2	Liquid	0.80	9.12	10.00		TWA	OSHA	YES	0.1	0.0	YES
124 Dimethylheptan-4-one, 2,6-	108-83-8	Liquid	0.80		25.00		TWA	ACGIH	YES	0.0	0.0	YES
125 Dimethylhydrazine, 1,1-	57-14-7	Liquid	1.00	7.3	0.06	8.800	Ceil	NIOSH	YES	503.1	3.5	QLP*
126 Dinitrobenzene, m-	99-65-0	Solid	3.00	10.43	0.45		TWA	NIOSH	YES	0.5	0.0	YES
127 Dinitrobenzene, o-	100-25-4	Solid	5.00		0.45		TWA	NIOSH	YES	0.5	0.0	YES
128 Dinonyl phthalate	84-76-4	Liquid	1.00		1000.00				YES	0.0	0.0	YES
129 Dioxane, 1,4-	123-91-1	Liquid	1.40	9.19	1.00		Ceil	ACGIH	YES	8.7	0.0	YES
130 Dipentene	138-86-3	Liquid	0.90		1000.00				YES	0.0	0.0	YES
131 Diphenyl ether	101-84-8	Liquid	0.80	8.09	1.00		STEL	ACGIH	YES	0.0	0.0	YES
132 Disulphur dichloride	10025-67-9	Liquid	3.00		1.00		Ceil	ACGIH	YES	2.1	0.0	YES
133 Di-tert-butyl-p-cresol	2409-55-4	Solid	1.00		1.00				YES	0.0	0.0	YES
134 Divinylbenzene	1321-74-0	Liquid	0.40		10.00		TWA	NIOSH	YES	0.0	0.0	YES
135 Dodecanol	112-53-8	Solid	0.90		1000.00				YES	0.0	0.0	YES
136 Enflurane	13838-16-9	Liquid	-		2.00				NO	26.1	0.0	YES
137 Epichlorohydrin	106-89-8	Liquid	7.60	10.2	1.51		TWA	ACGIH	YES	2.6	0.0	YES
138 Epoxypropyl isopropyl ether, 2,3-	4016-14-2	Liquid	1.10		50.50		Ceil	NIOSH	YES	0.1	0.0	YES
139 Ethanol	64-17-5	Liquid	10.02	10.5	997.09		STEL	ACGIH	YES	0.0	0.0	YES
140 Ethanolamine	141-43-5	Liquid	3.00	8.9	3.00		STEL	ACGIH	YES	0.0	0.0	YES
141 Ethoxy-2-propanol, 1-	1569-02-4	Liquid	2.00		1000.00				YES	0.0	0.0	YES
142 Ethoxyethanol, 2-	110-80-5	Liquid	29.80	9.6	1.47		TWA	NIOSH	YES	0.8	0.0	YES
143 Ethoxyethyl acetate, 2-	111-15-9	Liquid	3.00		1.50		TWA	NIOSH	YES	0.4	0.0	YES
144 Ethyl (S)-(-)-lactate	97-64-3	Liquid	3.00	10	1000.00				YES	0.0	0.0	YES
145 Ethyl Acetate	141-78-6	Liquid	4.20	10.11	1165.61		TWA	OSHA	YES	0.0	0.0	YES
146 Ethyl Acetoacetate	141-97-9	Liquid	0.90		1000.00				YES	0.0	0.0	YES
147 Ethyl Acrylate	140-88-5	Liquid	2.30	10.3	25.00		TWA	OSHA	YES	0.3	0.0	YES
148 Ethyl amine	75-04-7	Gas	1.00	8.9	10.00	0.324	STEL	NIOSH	YES	1.0	29.7	YES
149 Ethyl butyrate	105-54-4	Liquid	1.00		1000.00				YES	0.0	0.0	YES
150 Ethyl chloroformate	541-41-3	Liquid	80.00		1000.00				YES	0.0	0.0	YES
151 Ethyl cyanoacrylate	7085-85-0	Liquid	1.50		0.59		TWA	ACGIH	YES	0.2	0.0	YES
152 Ethyl decanoate	110-38-3	Liquid	1.80		1000.00				YES	0.0	0.0	YES
153 Ethyl Ether	60-29-7	Liquid	1.20	9.51	501.54	2.290	STEL	ACGIH	YES	0.3	57.4	YES
154 Ethyl formate	109-94-4	Liquid	30.00	10.6	296.96		TWA	OSHA	YES	0.2	0.0	YES

* "QLP" means Quantity Limitation Protocol Recommended

Compound	CAS Number	Liquid or Gas	RF	IP(eV)	Health Limits (PPM)	Odor Threshold (PPM)	OEL Type	OEL Agency	Detect?	Fan Inlet Spill Concentrations		Adequate Detection?
										Factor Above Health Limit	Factor Above Odor Threshold	
155 Ethyl hexanoate	123-66-0	Liquid	2.60		1000.00				YES	0.0	0.0	YES
156 Ethyl hexanol, 2-	105-76-7	Liquid	1.50		1000.00				YES	0.0	0.0	YES
157 Ethyl hexyl acrylate, 2-	103-11-7	Liquid	1.00		1000.00				YES	0.0	0.0	YES
158 Ethyl Mercaptan	75-08-1	Liquid	0.60	9.29	0.51	0.001	Ceil	NIOSH	YES	258.0	132066.1	QLP*
159 Ethyl octanoate	106-32-1	Liquid	2.30		1000.00				YES	0.0	0.0	YES
160 Ethylbenzene	100-41-4	Liquid	0.51	8.76	100.00		STEL	ACGIH	YES	0.0	0.0	YES
161 Ethylene	74-85-1	Gas	10.10	10.52	200.00		TWA	ACGIH	YES	0.0	0.0	YES
162 Ethylene Glycol	107-21-1	Liquid	15.70	10.2	40.00		Ceil	ACGIH	YES	0.0	0.0	YES
163 Ethylene Oxide	75-21-8	Gas	19.50	10.57	4.99	851.000	STEL	NIOSH	YES	1.9	0.0	YES
164 Ferrocene	102-54-5	Solid	0.80	6.88	3.93		TWA	NIOSH	YES	0.0	0.0	YES
165 Formamide	75-12-7	Liquid	2.00	10.2	10.00		TWA	NIOSH	YES	0.0	0.0	YES
166 Formic Acid	64-18-6	Liquid	-	11.05	5.00				NO	0.5	0.0	YES
167 Furfural	98-01-1	Liquid	1.40	9.2	6.03		TWA	ACGIH	YES	0.1	0.0	YES
168 Furfuryl alcohol	98-00-0	Liquid	2.00		14.95		STEL	ACGIH	YES	0.0	0.0	YES
169 Gasoline	8006-61-9	Liquid	1.10	<10.6	1000.00				YES	0.0	0.0	YES
170 Germane Tetrahydride	7782-65-2	Gas	-	11.34	0.20		TWA	NIOSH	NO	48.2	0.0	YES
171 Glutaraldehyde	111-30-8	Liquid	0.90		0.20		Ceil	ACGIH	YES	25.3	0.0	YES
172 Glycolonitrile	107-16-4	Liquid	-		2.00		Ceil	ACGIH	NO	0.1	0.0	YES
173 Halothane	151-67-7	Liquid	-	11	2.00		Ceil	ACGIH	NO	36.3	0.0	YES
174 Heptan-2-one	110-43-0	Liquid	0.70	9.3	149.65	0.141	TWA	ACGIH	YES	0.0	6.4	YES
175 Heptan-3-one	106-35-4	Liquid	0.80	9.02	74.93		STEL	ACGIH	YES	0.0	0.0	YES
176 Heptane	142-82-5	Liquid	2.50	10.08	439.22		Ceil	NIOSH	YES	0.0	0.0	YES
177 Hexamethyldisilazane, 1,1,1,3,3,3-	999-97-3	Liquid	1.00	<10.6	1000.00				YES	0.0	0.0	YES
178 Hexamethyldisiloxane	107-46-0	Liquid	0.30		1000.00				YES	0.0	0.0	YES
179 Hexan-2-one	591-78-6	Liquid	0.80	9.34	9.76		STEL	ACGIH	YES	0.3	0.0	YES
180 Hexane, n-	110-54-3	Liquid	4.50	10.18	149.76		TWA	ACGIH	YES	0.2	0.0	YES
181 Hexene, 1-	592-41-6	Liquid	0.90	9.4	149.91		TWA	ACGIH	YES	0.4	0.0	YES
182 Hexyl Acetate (sec-)	108-84-9	Liquid	-		50.00		TWA	NIOSH	NO	0.0	0.0	YES
183 Hydrazine	302-01-2	Liquid	2.60	8.1	0.03	3.600	Ceil	NIOSH	YES	97.7	0.8	YES
184 Hydrogen Bromide	10035-10-6	Gas	-	11.62	3.00		TWA	OSHA	NO	3.2	0.0	YES
185 Hydrogen Chloride	7647-01-0	Gas	-	12.74	5.00		REL	NIOSH	NO	1.9	0.0	YES
186 Hydrogen Cyanide	74-90-8	Liquid	-	13.6	4.70		REL	NIOSH	NO	40.1	0.0	YES
187 Hydrogen Fluoride	7664-39-3	Liquid	-	15.98	3.00		TWA	NIOSH	NO	78.0	0.0	YES
188 Hydrogen Peroxide	7722-84-1	Liquid	4.00	10.5	1.00		TWA	NIOSH	YES	1.5	0.0	YES
189 Hydrogen Selenide	7783-07-5	Gas	2.00	9.8	0.05		TWA	NIOSH	YES	192.7	0.0	YES
190 Hydrogen Sulfide	7783-06-4	Gas	3.20	10.46	10.76	0.130	Ceil	NIOSH	YES	0.9	74.1	YES
191 Hydroquinone	123-31-9	Solid	0.80	7.95	0.44		Ceil	NIOSH	YES	0.0	0.0	YES
192 Hydroxy-4-methyl-2-pentanone, 4-	123-42-2	Liquid	0.55		150.23		TWA	ACGIH	YES	0.0	0.0	YES
193 Hydroxypropyl acrylate, 2-	999-61-1	Liquid	1.50		1.58		TWA	ACGIH	YES	0.0	0.0	YES
194 Iminodi(ethylamine), 2,2-	111-40-0	Liquid	0.90		1.00		TWA	NIOSH	YES	0.1	0.0	YES
195 Iminodiethanol, 2,2'	111-42-2	Solid	1.60		3.00		TWA	ACGIH	YES	0.0	0.0	YES
196 Indene	95-13-6	Liquid	0.50		10.00		TWA	OSHA	YES	0.0	0.0	YES
197 Iodine	7553-56-2	Solid	0.20	9.4	0.10		Ceil	NIOSH	YES	0.9	0.0	YES
198 Iodoform	75-47-8	Solid	1.50		1.80		TWA	NIOSH	YES	0.0	0.0	YES
199 Iodomethane	74-88-4	Liquid	0.40		5.00		REL	OSHA	YES	23.9	0.0	YES
200 Iron Carbonyl	13463-40-6	Liquid	-		0.10		TWA	NIOSH	NO	119.5	0.0	YES
201 Isoamyl Acetate	123-92-2	Liquid	1.80		99.90		STEL	ACGIH	YES	0.0	0.0	YES
202 Isobutane	75-28-5	Gas	8.00	10.6	800.00		TWA	NIOSH	YES	0.0	0.0	YES
203 Isobutanol	78-83-1	Liquid	4.70	10.12	100.00		REL	OSHA	YES	0.0	0.0	YES
204 Isobutyl Acetate	110-19-0	Liquid	2.60	9.97	150.00		TWA	OSHA	YES	0.0	0.0	YES
205 Isobutyl Acrylate	106-63-8	Liquid	1.30		1000.00				YES	0.0	0.0	YES
206 Isobutylene	115-11-7	Gas	1.00	9.4	750.50		TWA	ACGIH	YES	0.0	0.0	YES
207 Isobutyraldehyde	78-84-2	Liquid	1.20		1000.00				YES	0.1	0.0	YES
208 Isodecanol	25339-17-7	Liquid	0.90		1000.00				YES	0.000	0.000	YES

* "QLP" means Quantity Limitation Protocol Recommended

Compound	CAS Number	Liquid or Gas	RF	IP(eV)	Health Limits (PPM)	Odor Threshold (PPM)	OEL Type	OEL Agency	Detect?	Fan Inlet Spill Concentrations		Adequate Detection?
										Factor Above Health Limit	Factor Above Odor Threshold	
209 Isooctane	540-84-1	Liquid	1.30		385.38		Ceil	NIOSH	YES	0.0	0.0	YES
210 Isooctanol	26952-21-6	Liquid	1.70		50.00		TWA	ACGIH	YES	0.0	0.0	YES
211 Isopentane	78-78-4	Liquid	8.00	10.32	609.98		Ceil	NIOSH	YES	0.3	0.0	YES
212 Isophorone	78-59-1	Liquid	0.74	9.07	4.95		Ceil	ACGIH	YES	0.0	0.0	YES
213 Isoprene	78-79-5	Liquid	0.60	8.85	1000.00				YES	0.2	0.0	YES
214 Isopropanol	67-63-0	Liquid	5.55	10.12	400.31		STEL	ACGIH	YES	0.0	0.0	YES
215 Isopropyl Acetate	108-21-4	Liquid	2.60	9.99	250.00		PEL	OSHA	YES	0.1	0.0	YES
216 Isopropyl chloroformate	108-23-6	Liquid	1.60		1000.00				YES	0.0	0.0	YES
217 Isopropyl Ether	108-20-3	Liquid	0.80	9.2	311.01	0.017	STEL	ACGIH	YES	0.1	2091.5	QLP*
218 Isopropylamine	75-31-0	Liquid	0.90	8.72	5.00	0.210	TWA	OSHA	YES	27.5	654.5	QLP*
219 Jet A fuel	8008-20-6	Liquid	0.40	<10.6	36.68		TWA	NIOSH	YES	0.0	0.0	YES
220 JP-5 fuel	8008-20-6	Liquid	0.48	<10.6	36.68		TWA	NIOSH	YES	0.0	0.0	YES
221 JP-8 fuel	8008-20-6	Liquid	0.48	<10.6	36.68		TWA	NIOSH	YES	0.0	0.0	YES
222 Ketene	463-51-4	Gas	3.00	9.61	0.50		REL	ACGIH	YES	19.3	0.0	YES
223 Maleic anhydride	108-31-6	Solid	2.00	10.8	0.25		TWA	NIOSH	YES	0.2	0.0	YES
224 Mercaptoacetic acid	68-11-1	Liquid	1.00		1.00		TWA	ACGIH	YES	3.0	0.0	YES
225 Mesityl Oxide	141-79-7	Liquid	0.47	9.08	24.90	0.056	STEL	ACGIH	YES	0.1	48.0	YES
226 Methacrylic acid	79-41-4	Liquid	2.30		59.70		TWA	ACGIH	YES	0.0	0.0	YES
227 Methacrylonitrile	126-98-7	Liquid	5.00		1.00		REL	NIOSH	YES	21.2	0.0	YES
228 Methane	74-82-8	Gas	-	NA	1000.00		TWA	ACGIH	NO	0.0	0.0	YES
229 Methanol	67-56-1	Liquid	-	NA	200.00		TWA	NIOSH	NO	0.1	0.0	YES
230 Methoxy-2-Propanol, 1-	107-98-2	Liquid	1.40	9.54	100.00		TWA	NIOSH	YES	0.0	0.0	YES
231 Methoxyethoxyethanol, 2-	111-77-3	Liquid	1.40		1000.00				YES	0.0	0.0	YES
232 Methoxymethylethoxy-2-propanol	34590-94-8	Liquid	1.30		100.00		TWA	NIOSH	YES	0.0	0.0	YES
233 Methoxypropyl acetate	108-65-6	Liquid	1.20		1000.00				YES	0.0	0.0	YES
234 Methyl Acetate	79-20-9	Liquid	7.00	10.27	200.00		TWA	NIOSH	YES	0.3	0.0	YES
235 Methyl Acetoacetate	105-45-3	Liquid	1.09		1000.00				YES	0.0	0.0	YES
236 Methyl Acrylate	96-33-3	Liquid	3.40	9.9	10.00		TWA	NIOSH	YES	1.9	0.0	YES
237 Methyl Benzoate	93-58-3	Liquid	0.93		1000.00				YES	0.0	0.0	YES
238 Methyl cyanoacrylate	137-05-3	Liquid	5.00		3.52		STEL	NIOSH	YES	0.0	0.0	YES
239 Methyl Ethyl Ketone	78-93-3	Liquid	0.90	9.54	200.00		TWA	NIOSH	YES	0.1	0.0	YES
240 Methyl Ethyl Ketone peroxides	1338-23-4	Liquid	0.80		0.21		Ceil	ACGIH	YES	0.0	0.0	YES
241 Methyl Isobutyl Ketone	108-10-1	Liquid	1.10	9.3	73.20		STEL	NIOSH	YES	0.1	0.0	YES
242 Methyl isothiocyanate	556-61-6	Liquid	0.60		1000.00				YES	0.0	0.0	YES
243 Methyl Mercaptan	74-93-1	Gas	0.60	9.44	0.51	0.001	Ceil	NIOSH	YES	19.0	9634.8	QLP*
244 Methyl Methacrylate	80-62-6	Liquid	1.50	9.7	100.14	0.085	STEL	NIOSH	YES	0.1	101.9	YES
245 Methyl salicylate	119-36-8	Liquid	1.20		1000.00				YES	0.0	0.0	YES
246 Methyl sulphide	75-18-3	Liquid	0.50		29.53		TWA	ACGIH	YES	4.0	0.0	YES
247 Methyl tert-Butyl Ether	1634-04-4	Liquid	0.86		150.03		TWA	ACGIH	YES	0.5	0.0	YES
248 Methyl-2-propen-1-ol, 2-	51-42-8	Liquid	1.10		1000.00				YES	0.0	0.0	YES
249 Methyl-2-pyrrolidinone, N-	872-50-4	Liquid	0.90		1000.00				YES	0.0	0.0	YES
250 Methyl-4,6-dinitrophenol, 2-	534-52-1	Solid	3.00		0.20		TWA	NIOSH	YES	0.0	0.0	YES
251 Methyl-5-hepten-2-one, 6-	110-93-0	Liquid	0.80		1000.00				YES	0.0	0.0	YES
252 Methylamine	74-89-5	Gas	1.15	8.97	14.94	0.019	STEL	ACGIH	YES	0.6	507.1	QLP*
253 Methylbenzyl alcohol	89-95-2	Solid	0.80		1000.00				YES	0.0	0.0	YES
254 Methylbutan-1-ol, 3-	123-51-3	Liquid	3.40		124.74		STEL	NIOSH	YES	0.1	0.0	YES
255 Methylcyclohexane	108-87-2	Liquid	1.10		400.00		TWA	NIOSH	YES	0.0	0.0	YES
256 Methylcyclohexanol, 4-	589-91-3	Liquid	2.40		1000.00				YES	0.0	0.0	YES
257 Methylcyclohexanone, 2-	583-60-8	Liquid	1.00		74.96		STEL	ACGIH	YES	0.0	0.0	YES
258 Methylene Chloride	75-09-2	Liquid	-	NA	125.00		STEL	OSHA	NO	0.8	0.0	YES
259 Methylheptan-3-one, 5-	541-85-5	Liquid	0.80		74.50		TWA	NIOSH	YES	0.0	0.0	YES
260 Methylhexan-2-one, 5-	110-12-3	Liquid	0.80		100.00		PEL	OSHA	YES	0.0	0.0	YES

* "QLP" means Quantity Limitation Protocol Recommended

Compound	CAS Number	Liquid or Gas	RF	IP(eV)	Health Limits (PPM)	Odor Threshold (PPM)	OEL Type	OEL Agency	Detect?	Fan Inlet Spill Concentrations		Adequate Detection?
										Factor Above Health Limit	Factor Above Odor Threshold	
261 Methyl-N-2,4,6-tetranitroaniline, N-	479-45-8	Solid	3.00		0.38		TWA	NIOSH	YES	0.8	0.0	YES
262 Methylpentan-2-ol, 4-	108-11-2	Liquid	2.80		39.47		STEL	NIOSH	YES	0.0	0.0	YES
263 Methylpentane-2,4-diol, 2-	107-41-5	Liquid	4.00		25.07		Ceil	ACGIH	YES	0.0	0.0	YES
264 Methylstyrene	25013-15-4	Liquid	0.50	8.2	99.91		STEL	ACGIH	YES	0.0	0.0	YES
265 Methoxyethanol, 2-	109-86-4	Liquid	2.50	9.6	0.29		TWA	ACGIH	YES	6.2	0.0	YES
266 Mineral Oil	8042-47-5	Liquid	0.80	<10.6	1000.00				YES	0.0	0.0	YES
267 Mineral spirits	64475-85-0	Liquid	0.80	<10.6	1000.00				YES	0.0	0.0	YES
268 Naphthalene	91-20-3	Solid	0.37	8.12	10.00		TWA	NIOSH	YES	0.0	0.0	YES
269 Nitric Acid	7697-37-2	Liquid	-	11.95	2.00		TWA	NIOSH	NO	7.2	0.0	YES
270 Nitric Oxide	10102-43-9	Gas	7.20	9.25	25.00	1.000	TWA	NIOSH	YES	0.4	9.6	YES
271 Nitroaniline, 4-	100-01-6	Solid	0.80		1.59		TWA	NIOSH	YES	0.0	0.0	YES
272 Nitrobenzene	98-95-3	Liquid	1.70	9.8	1.00		TWA	OSHA	YES	0.1	0.0	YES
273 Nitrogen dioxide	10102-44-0	Liquid	10.00	9.8	0.96	0.190	STEL	NIOSH	YES	224.9	1132.3	QLP*
274 Nitrogen trichloride	10025-85-1	Liquid	1.00		1000.00				YES	0.0	0.0	YES
275 Nitromethane	75-52-5	Liquid	-	11.08	100.00		TWA	OSHA	NO	0.1	0.0	YES
276 Nonane, n-	111-84-2	Liquid	1.60	10.6	200.00		TWA	NIOSH	YES	0.0	0.0	YES
277 Norbornadiene, 2,5-	121-46-0	Liquid	0.60		1000.00				YES	0.0	0.0	YES
278 Octachloronaphthalene	2234-13-1	Solid	1.00		0.02		STEL	NIOSH	YES	14.9	0.0	YES
279 Octane	111-65-9	Liquid	2.20	9.82	385.38		Ceil	NIOSH	YES	0.0	0.0	YES
280 Octene, 1-	111-66-0	Liquid	0.70		1000.00				YES	0.0	0.0	YES
281 Oxydiethanol, 2,2-	111-46-6	Liquid	4.00		1000.00				YES	0.0	0.0	YES
282 Paraffin wax, fume	8002-74-2	Solid	1.00	<10.6	1000.00				YES	0.0	0.0	YES
283 Paraffin wax, normal	64771-72-8	Solid	1.00	<10.6	1000.00				YES	0.0	0.0	YES
284 Pentacarbonyl iron	13463-40-6	Liquid	1.00		0.06		STEL	ACGIH	YES	212.9	0.0	YES
285 Pentadione, 2,4-	123-54-6	Liquid	0.80		1000.00				YES	0.0	0.0	YES
286 Pentan-3-one	96-22-0	Liquid	0.80		300.16		STEL	ACGIH	YES	0.0	0.0	YES
287 Pentane, n-	109-66-0	Gas	9.73	10.3	10.00		Ceil	ACGIH	YES	1.0	0.0	YES
288 Pentanone, 2-	107-87-9	Liquid	0.78	9.38	150.22		STEL	ACGIH	YES	0.1	0.0	YES
289 Peracetic acid	79-21-0	Liquid	2.00		1000.00				YES	0.0	0.0	YES
290 Phenol	108-95-2	Solid	1.00	8.5	15.59		Ceil	NIOSH	YES	0.0	0.0	YES
291 Phenylenediamine, p-	106-50-3	Solid	0.60	6.89	0.07		TWA	NIOSH	YES	4.4	0.0	YES
292 Phenyl propene, 2-	98-83-9	Liquid	0.40		99.29		Ceil	OSHA	YES	0.0	0.0	YES
293 Phenyl-2,3-epoxypropyl ether	122-60-1	Liquid	0.80		0.98		Ceil	NIOSH	YES	0.0	0.0	YES
294 Phosphine	7803-51-2	Gas	2.80	9.87	0.72	0.140	STEL	NIOSH	YES	13.4	68.8	YES
295 Phosgene	75-44-5	Gas	-	11.55	0.10		REL	NIOSH	NO	96.3	0.0	QLP*
296 Picoline, 2-	109-06-8	Liquid	0.57		1000.00				YES	0.0	0.0	YES
297 Picoline, 3-	108-99-6	Liquid	0.90	9	1000.00				YES	0.0	0.0	YES
298 Pinene, alpha-	80-56-8	Liquid	0.40	8.1	60.30		TWA	ACGIH	YES	0.0	0.0	YES
299 Pinene, beta-	127-91-3	Liquid	0.40	8.1	60.36		TWA	ACGIH	YES	0.0	0.0	YES
300 Piperidine	110-89-4	Liquid	0.90		1000.00				YES	0.0	0.0	YES
301 Piperylene	504-60-9	Liquid	0.70		1000.00				YES	0.1	0.0	YES

* "QLP" means Quantity Limitation Protocol Recommended

Compound	CAS Number	Liquid or Gas	RF	IP(eV)	Health Limits (PPM)	Odor Threshold (PPM)	OEL Type	OEL Agency	Detect?	Fan Inlet Spill Concentrations		Adequate Detection?
										Factor Above Health Limit	Factor Above Odor Threshold	
302 Prop-2-yn-1-ol	107-19-7	Liquid	1.30		2.62		TWA	NIOSH	YES	1.4	0.0	YES
303 Propane-1,2-diol, total	57-55-6	Liquid	10.00		1000.00				YES	0.0	0.0	YES
304 Propanol, 1-	71-23-8	Liquid	5.70	10.2	200.00		TWA	NIOSH	YES	0.0	0.0	YES
305 Propionaldehyde (propanal)	123-38-6	Liquid	14.80	9.98	60.60		TWA	ACGIH	YES	0.0	0.0	YES
306 Propionic acid	79-09-4	Liquid	8.00		15.72		STEL	NIOSH	YES	0.1	0.0	YES
307 Propyl acetate, n-	109-60-4	Liquid	3.10	10.04	248.81	0.575	STEL	ACGIH	YES	0.0	13.0	YES
308 Propylene	115-07-1	Gas	1.30	9.73	1498.36		TWA	ACGIH	YES	0.0	0.0	YES
309 Propylene Oxide	75-56-9	Liquid	6.50	10.22	100.00		TWA	OSHA	YES	1.3	0.0	YES
310 Propyleneimine	75-55-8	Liquid	1.30	9	2.00		TWA	NIOSH	YES	16.7	0.0	YES
311 Pyridine	110-86-1	Liquid	0.79	9.32	5.00		TWA	NIOSH	YES	1.0	0.0	YES
312 Pyridylamine, 2-	504-29-0	Solid	0.80		0.50		TWA	NIOSH	YES	0.5	0.0	YES
313 Quinoline	91-22-5	Liquid	0.72		1000.00				YES	0.0	0.0	YES
314 Styrene	100-42-5	Liquid	0.40	8.47	40.00		STEL	ACGIH	YES	0.0	0.0	YES
315 Sulfuric Acid	7664-93-9	Liquid	-		0.25		TWA	NIOSH	NO	0.0	0.0	YES
316 Terpinolene	586-62-9	Liquid	0.50		1000.000				YES	0.0	0.0	YES
317 Tetrabromoethane, 1,1,2,2-	79-27-6	Liquid	2.00		0.30		TWA	ACGIH	YES	0.0	0.0	YES
318 Tetracarbonylnickel	13463-39-3	Liquid	1.00	8.28	0.001	1.000	TWA	OSHA	YES	94119.1	94.1	QLP*
319 Tetrachloroethylene	127-18-4	Liquid	0.56	9.32	101.01		STEL	ACGIH	YES	0.0	0.0	YES
320 Tetrachloronaphthalenes, all isomers	20020-02-4	Solid	1.00		1000.00				YES	0.0	0.0	YES
321 Tetraethyl orthosilicate	78-10-4	Liquid	2.00	9.8	10.00		TWA	ACGIH	YES	0.0	0.0	YES
322 Tetrafluoroethylene	116-14-3	Gas	1.00		6.01		TWA	ACGIH	YES	1.6	0.0	YES
323 Tetrahydrofuran	109-99-9	Liquid	1.60	9.54	200.00		TWA	NIOSH	YES	0.2	0.0	YES
324 Tetramethyl succinonitrile	3333-52-6	Solid	1.00		1.50		TWA	NIOSH	YES	0.0	0.0	YES
325 Thiophene	110-02-1	Liquid	0.47	8.86	1000.00				YES	0.0	0.0	YES
326 Toluene	108-88-3	Liquid	0.53	8.82	148.66		STEL	NIOSH	YES	0.0	0.0	YES
327 Toluene-2,4-diisocyanate	584-84-9	Solid	1.60		0.02		STEL	ACGIH	YES	0.1	0.0	YES
328 Toluenesulphonylchloride, p-	98-59-9	Solid	3.00		1000.00				YES	0.0	0.0	YES
329 Toluidine, o-	95-53-4	Liquid	0.50	7.44	6.02		TWA	ACGIH	YES	0.0	0.0	YES
330 Tributyl phosphate	126-73-8	Liquid	5.00		0.61		TWA	ACGIH	YES	0.0	0.0	YES
331 Tributylamine	102-82-9	Liquid	1.00		1000.00				YES	0.0	0.0	YES
332 Trichlorobenzene, 1,2,4-	120-82-1	Liquid	0.60		5.00		Ceil	ACGIH	YES	0.1	0.0	YES
333 Trichloroethylene	79-01-06	Liquid	0.50	9.47	2.00		Ceil	NIOSH	YES	8.7	0.0	YES
334 Trichlorophenoxyacetic acid, 2,4,5-	93-76-5	Solid	1.00		2.87		TWA	NIOSH	YES	0.0	0.0	YES
335 Triethylamine	121-44-8	Liquid	0.90	7.5	3.00	0.001	STEL	ACGIH	YES	5.4	16134.0	QLP*
336 Trimethylamine	75-50-3	Gas	0.83	7.82	14.89		STEL	NIOSH	YES	0.6	0.0	YES
337 Trimethylbenzene, 1,2,3-	526-73-8	Liquid	0.49	8.48	75.06		TWA	ACGIH	YES	0.0	0.0	YES
338 Trimethylbenzene, 1,2,4-	95-63-6	Liquid	0.43	8.27	75.06		TWA	ACGIH	YES	0.0	0.0	YES
339 Trimethylbenzene, 1,3,5-	108-67-8	Liquid	0.34	8.39	75.06		TWA	ACGIH	YES	0.0	0.0	YES
340 Turpentine -crude sulfite	8006-64-2	Liquid	1.00	<10.6	60.36		TWA	ACGIH	YES	0.0	0.0	YES
341 Turpentine -pure gum	8006-64-2	Liquid	0.45	<10.6	302.03		TWA	OSHA	YES	0.0	0.0	YES
342 Undecane, n-	1120-21-4	Liquid	0.90	9.6	1000.00				YES	0.0	0.0	YES
343 Vinyl Acetate	108-05-04	Liquid	1.30	9.19	4.26		Ceil	NIOSH	YES	5.8	0.0	YES
344 Vinyl Bromide	593-60-2	Gas	0.40	9.8	1.51		TWA	ACGIH	YES	6.4	0.0	YES
345 Vinyl Chloride	75-01-4	Gas	1.80	10	5.00		STEL	OSHA	YES	1.9	0.0	YES
346 Vinyl-2-pyrrolidinone, 1-	88-12-0	Solid	0.90		0.15		TWA	ACGIH	YES	0.2	0.0	YES
347 Vinylidene Chloride (1,1-DCE)	75-35-4	Liquid	0.80	10	15.12		TWA	ACGIH	YES	9.9	0.0	YES
348 Xylene, m-	108-38-3	Liquid	0.53	8.56	149.88		STEL	ACGIH	YES	0.0	0.0	YES
349 Xylene, o-	95-47-6	Liquid	0.54	8.56	149.88		STEL	ACGIH	YES	0.0	0.0	YES
350 Xylene, p-	106-42-3	Liquid	0.50	8.44	149.88		STEL	ACGIH	YES	0.0	0.0	YES
351 Xylenes, mixed isomers	1330-20-7	Liquid	0.40	8.6	149.88		STEL	ACGIH	YES	0.0	0.0	YES
352 Xylidine, all	1300-73-8	Liquid	0.70	7.65	1.51	0.010	TWA	ACGIH	YES	0.2	29.8	YES

* "QLP" means Quantity Limitation Protocol Recommended